


## SOUTH DAKOTA WATER WELL COMPLETION REPORT

11-02

Location SE 1/4 1/4 Sec 12 Twp 119 Rg 61County Spink

North

Please mark well  
location with an "X"

Well Completion Date

11/11/2014

1 Mile

Distance to nearest potential pollution source (septic tank, abandoned well, feed lot, etc.)?  
none ft. from (identify source)

## PROPOSED USE:

☒ Domestic/Stock ☐ Municipal ☐ Business ☐ Test holes  
☐ Irrigation ☐ Industrial ☐ Institutional ☐ Monitoring well

## METHOD OF DRILLING:

Mud Rotary

## CASING DATA:

If other describe

☐ Steel ☒ Plastic ☐ Other

PIPEWEIGHT	DIAMETER	FROM	TO	HOLE DIAMETER
200 LB/FT	5 IN	0 FT	120 FT	7 7/8 IN
Sch 80 LB/FT	2 IN	120 FT	980 FT	4 1/2 IN
LB/FT	IN	FT	FT	IN

## GROUTING DATA:

Grout Type	No. of Sacks	Grout Weight	From	To
		Lb/gal	Ft	Ft
		Lb/gal	Ft	Ft

Describe grouting procedure

## SCREEN:

☒ Perforated pipe ☐ Manufactured
Diameter 2" Inches Length 180 FeetMaterial PVCSlot Size 3/8 Set From 800 Feet to 980 Feet

Other information

## WAS A PACKER OR SEAL USED?

☒ Yes ☐ No
If so, what material? Rubber

Describe packer(s) and location

Above Perforation

## DISINFECTION: Was well disinfected upon completion?

☒ Yes, How? Chlorine
Lab to which water ☐ No, Why Not?

quality sample sent for analysis

Well Owner: Daelynn Dirksen

Business Name:

Address: 40580 156th StCity, State, Zip: Conde SD 57434

## WELL LOG:

FORMATION	DEPTH	
	FROM	TO
Top Soil	0	5
Yellow Clay	2	25
Blue Clay	25	60
Shale	60	800
Dakota	800	980

## STATIC WATER LEVEL

FEET

If flowing: closed in pressure 5 PSIGPM flow 12 through 2" Inch pipeControlled by ☒ Valve ☐ Reducers ☐ Other

Reduced flow rate \_\_\_\_\_ GPM

Can well be completely shut in? Yes

## WELL TEST DATA:

☐ Pumped Describe:☐ Bailed☐ Other

Pumping Level Below Land Surface

\_\_\_\_\_ Ft. After \_\_\_\_\_ Hrs. pumped \_\_\_\_\_ GPM

\_\_\_\_\_ Ft. After \_\_\_\_\_ Hrs. pumped \_\_\_\_\_ GPM

If pump installed, pump rate: \_\_\_\_\_ GPM

## REMARKS

RECEIVED

JAN 21 2015

WATER RIGHTS  
PROGRAMThis well was drilled under license # 722 and this report is true and accurate.Drilling firm: Stretch's Well Service Inc.

Signature of License Representative:

Signature of Well Owner or Equitable Property Holder:

Date: 19 Dec 14